



Northbrook, Illinois • (847) 272-8800  
 Melville, New York • (516) 271-6200  
 Santa Clara, California • (408) 985-2400  
 Research Triangle Park,  
 North Carolina • (919) 549-1400  
 Camas, Washington • (360) 817-5500

# CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 101198 - R3407D  
 ISSUE DATE: November 10, 1998

Issued to: Armstrong World Industries Inc.  
 R & D Center, 2500 Columbia Ave.  
 Lancaster, PA 17604 USA

Report Reference: R3407, May 10, 1968

This is to Certify that representative samples of: Coated or Polyester Film Faced Mineral-Wool Acoustical Tile, Designated as "Type XLD".

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 723, Test for Surface Burning Characteristics of Building Materials (ASTM E84, NFPA 255).

**Additional Information:**

*These are coated or polyester film faced tiles which is produced in a nominal thickness of 1/2 to 1-1/4 in. Density: 7.2 to 21.6 pcf. Surface Burning Characteristics vary depending on the coating system used and may be:*


<i>Flame Spread</i>	<i>25</i>	<i>Or</i>	<i>Flame Spread</i>	<i>25</i>
<i>Smoke Developed</i>	<i>10</i>		<i>Smoke Developed</i>	<i>50</i>


*Polyester film faced tiles may be additionally coated on the face and back surfaces.*

**Only those products bearing the UL Classification Marking should be considered as being covered by UL's Classification and Follow-Up Service**

The UL Classification Marking includes: the name "Underwriters Laboratories Inc." the word "Classified"; a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

**LOOK FOR THE UL CLASSIFICATION MARKING ON THE PRODUCT**

Engineer:   
 Underwriters Laboratories Inc.  
 Dorothy Trawkowska

Review Engineer:   
 Underwriters Laboratories Inc.  
 Craig Gatto